



Entwicklungs- und Prüflabor  
Holztechnologie GmbH  
Zellescher Weg 24 · D-01217 Dresden  
www.eph-dresden.de



Deutsche  
Akkreditierungsstelle  
D-PL-11054-01-00  
D-ZE-11054-01-00

accredited by Deutsche Akkreditierungsstelle GmbH (DAkkS)

Deutsches  
Institut  
für  
Bautechnik



European Notified Body for construction products 0766  
Recognized body of DIBt SAC03

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-13-12-20-01

**Products:** Variant 1: "Vinylan plus" Designvinyl – finished floor, thickness: 11 mm

**Producer:** Corkart – Industria de Corticas Ltd.  
Parque Industrial de Vendas Novas, Lt 20  
7080-341 VENDAS NOVAS  
PORTUGAL

**Order:** Testing and classification of selected properties according to EN 14041  
(CE-labelling)

**Test report:** 279238

**Test results:**

Property	Declaration according to EN 14041
Fire resistance according to EN 9239-1 and EN ISO 11925-2, classification according to EN 13501-1	B <sub>fl</sub> -s1
Formaldehyde emission according to EN 717-1	class E1
Anti-sliding properties according EN 13893	class DS
Content of PCP according to CEN/TR 14823	not to declare

Dresden, 20 December 2013



*R. Gumbler*

Head of laboratory

*J. V. ...*

Engineer in charge